



STATE OF NORTH CAROLINA
DEPARTMENT OF TRANSPORTATION

ROY COOPER
GOVERNOR

JAMES H. TROGDON, III
SECRETARY

October 18, 2017

ADDENDUM # 1

To: Plan Holders



From: Wes Jamison, P.E.
Division 14 Project Manager

RE: **Question & Answer**
Contract ID: DN00626
County: Haywood
Letting Date: October 19, 2017

Please see the following questions and corresponding answers about the above contract:

Question 1: Can the asphalt testing requirements be waived?

Answer 1: No, the asphalt testing requirements be cannot be waived, however the testing results can be waived.

Question 2: Can the minimum asphalt placement temperature for surface course and friction course be waived or lowered?

Answer 2: The minimum asphalt placement temperature for surface course and friction course cannot be waived, but for this project, the minimum asphalt placement temperature for surface course and friction course may be lowered to 40 degrees Fahrenheit.

These revisions do not change bid items or the associated quantities.

Please access ebs addenda files on Bid Express®.

Please insert this letter into the addendum section of the proposal and sign the verification. Thank you for your attention to this matter.